


Certificate of Conformity

Certificate Number: CN-PVES-250001

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Shenzhen Growatt New Energy Co., Ltd 4-13/F, Building A, Sino-German (Europe) Industrial Park, Hangcheng Ave, Bao'an District, Shenzhen, China
Product:	Hybrid Inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	WIT 8K-HU, WIT 10K-HU, WIT 12K-HU, WIT 15K-HU
Brand Name<s>:	GROWATT
Product Complies with:	IEC61683:1999 Photovoltaic systems – Power conditioners – Procedure for measuring efficiency IEC 60068-2-1:2007, IEC 60068-2-2:2007, IEC60068-2-14:2009, IEC60068-2-30:2005
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	240920055GZU-001, 30 December 2024 240920056GZU-001, 30 December 2024

Additional information in Appendix.



Signature

Certification Manager: Grady Ye

Date: 02 January 2025



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number:CN-PVES-250001.

Model	WIT 8K-HU		WIT 10K-HU
PV Data			
Max. PV voltage	1000 d.c.V		
PV voltage range	320-750 d.c.V	400-750 d.c.V	
Nominal input voltage	600 d.c.V		
PV Isc	25 d.c.A*2		
Max. input current	20 d.c.A*2		
Max. PV power	12.8 KW	16 KW	
Number of MPP trackers	2		
AC Data			
Nominal output voltage	3W/N/PE 380/400 a.c.V		
Nominal output Frequency	50/60Hz		
Max. input/output power	16/8 kW	20/10 kW	
Max. input/output apparent power	17.6/8.8 kVA	22/11 kVA	
Max. output current	26.6/13.3 a.c.A	33.3/16.7 a.c.A	
Power factor range	1.0 leading ~ 1.0 lagging		
Load Data			
Nominal output voltage	3W/N/PE 380/400 a.c.V		
Nominal output Frequency	50/60Hz		
Max. output power	8 kW	10 kW	
Power factor range	1.0 leading ~ 1.0 lagging		
GEN Data			
Nominal output voltage	3W/N/PE 380/400 a.c.V		
Nominal output Frequency	50/60Hz		
Max. output power	16 kW	20 kW	
Battery Data			
Battery Type	Lithium-ion/VRLA		
Battery voltage range	42.6-60 d.c.V	48.4-60 d.c.V	
Max. charging and discharging current	200 d.c.A	220 d.c.A	
Other Data			
Safety level	Class I		
Ingress Protection	IP66		
Operation ambient temperature	-30°C ~ +60°C (>45°C Derating)		
Software version	TO 1.0		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250001.

Model	WIT 12K-HU	WIT 15K-HU
PV Data		
Max. PV voltage	1000 d.c.V	
PV voltage range	320-750 d.c.V	400-750 d.c.V
Nominal input voltage	600 d.c.V	
PV Isc	25 d.c.A*3	
Max. input current	20 d.c.A*3	
Max. PV power	19.2 KW	24 KW
Number of MPP trackers	3	
AC Data		
Nominal output voltage	3W/N/PE 380/400 a.c.V	
Nominal output Frequency	50/60Hz	
Max. input/output power	24/12 kW	30/15 kW
Max. input/output apparent power	26.4/13.2 kVA	33/16.5 kVA
Max. input/output current	40/20 a.c.A	50.1/25 a.c.A
Power factor range	1.0 leading ~ 1.0 lagging	
Load Data		
Nominal output voltage	3W/N/PE 380/400 a.c.V	
Nominal output Frequency	50/60Hz	
Max. output power	12 kW	15 kW
Power factor range	1.0 leading ~ 1.0 lagging	
GEN Data		
Nominal output voltage	3W/N/PE 380/400 a.c.V	
Nominal output Frequency	50/60Hz	
Max. output power	24 KW	30 KW
Battery Data		
Battery Type	Lithium-ion/VRLA	
Battery voltage range	51-60 d.c.V	55-60 d.c.V
Max. charging and discharging current	250 d.c.A	290 d.c.A
Other Data		
Safety level	Class I	
Ingress Protection	IP66	
Operation ambient temperature	-30℃ ~ +60℃ (>45℃ Derating)	
Software version	TO 1.0	

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.